

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 02/16/2011
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155770		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED 02/14/2011	
NAME OF PROVIDER OR SUPPLIER VILLAS OF GUERIN WOODS				STREET ADDRESS, CITY, STATE, ZIP CODE 1002 SISTER BARBARA WAY GEORGETOWN, IN 47122			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p>INITIAL COMMENTS</p> <p>A Life Safety Code Recertification and State Licensure Survey was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 02/14/11</p> <p>Facility Number: 011509 Provider Number: 155770 AIM Number: 200909280</p> <p>Surveyor: Mark Bugni, Life Safety Code Specialist</p> <p>At this Life Safety Code survey, Villas of Guerin Woods was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 18, New Health Care Occupancies and 410 IAC 16.2.</p> <p>Villas of Guerin Woods consists of three separate, one story buildings determined to be of Type V (111) construction and fully sprinklered. All buildings have a fire alarm system with smoke detection in the corridors, spaces open to the corridors, and all resident sleeping rooms. Building 1002 has a capacity of 10 and a census of 9, building 1003 has a capacity of 10 and a census of 10, and building 1004 has a capacity of 10 and had a census of 10 at the time of this visit.</p> <p>Quality Review by Robert Booher, REHS, Life Safety Code Specialist-Medical Surveyor on 02/15/11.</p>			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.